

Date: August 14, 2024 Permit No.: 2024-00130
To: Matthew Mandich Community Development
From: Shehriyar Bukhari Public Works (sbukhari@sausalito.gov)
Re: 388/390 Sausalito Blvd; APN 065-252-22
Department of Public Works (DPW) Engineering Review Comments

DPW has reviewed the material submitted for the referenced project and find the application **Incomplete**.

DPW has reviewed:

- Plans by DAC (dated: 2023-12-11)

The following detailed comments shall be addressed prior to the issuance of a building permit. Please respond to each comment on a formal response memo back to DPW explaining how and where they are addressed on the plans (if at all).

Grading / Geotechnical Items

- 1) Grading permits shall be obtained from DPW for earthwork of 50 cubic yards or more. No cut and fill quantities provided. Please apply for a grading permit by reaching out to Megan Lockett at mlockett@sausalito.gov.